

eco-INSTITUT, Schanzenstr. 6-20, D-51063 Köln

Hilti Entwicklungsgesellschaft mbH
 Mrs. Sarah Kretschmer
 Hiltistraße 6
 86916 Kaufering

Dear Mrs. Kretschmer,

based on the evaluation of the Test Reports No. 60617-A001-CS-L dated 2026-01-07, the testing results of the product **CF-AS CJP** commissioned by **Hilti Entwicklungsgesellschaft mbH** comply with the requirements of

- VOC product emissions acc. to California Department of Public Health (CDPH) Standard Method v1.2-2017 (California Specification 01350 (01/2017))

These criteria meet the requirements for low-emitting **Insulation** in credit EQc2 of the LEEDv4 Rating System and the LEEDv4.1 Rating System as well as credit MRc3 of the LEEDv5 Rating System.

Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Exposure Scenario	Individual VOCs of Concern		Formaldehyde		TVOC (ISO 16000-6)
	Requirement	Requirement hold	Requirement	Requirement hold	Range
School Classroom	½ CREL	yes	≤ 9 µg/m³	yes	≤ 0.5 mg/m³
Private Office	½ CREL	yes	≤ 9 µg/m³	yes	≤ 0.5 mg/m³

Application amount: 3 grams

Cologne, 2026-01-07



Marc-Anton Dobaj, M.Sc. Crystalline Materials
(Project manager)